

# Ground Loop Design

## Zone Report - Loads - 4/3/2015



<b>Project Name:</b> Geothermal Design	
<b>Designer Name:</b> Designer	<b>Project Start Date:</b> 4/3/2015
<b>Date:</b> 4/3/2015	
<b>Client Name:</b> Test Design	
<b>Address Line 1:</b>	
<b>Address Line 2:</b>	
<b>City:</b> Metropolis	<b>Phone:</b>
<b>State:</b> CA	<b>Fax:</b>
<b>Zip:</b> 12345	<b>Email:</b>

### Design Day Loads (kBtu/hr)

Zone	Mode	8 a.m. - Noon	Noon - 4 p.m.	4 p.m. - 8 p.m.	8 p.m. - 8 a.m.	Hours	Days per Week
<b>1</b>	Cooling	254.8	337.5	344.7	275.1	1908.	7.0
	Heating	378.8	237.7	212.8	345.3	1220.	

### Monthly Loads Data

	Cooling		Heating	
	Total (kBtu)	Peak (kBtu/hr)	Total (kBtu)	Peak (kBtu/hr)
January	576	34	122743	399
February	2215	81	82873	352
March	13404	123	51188	272
April	24062	138	25205	235
May	73990	260	9659	148
June	119183	337	4090	110
July	161268	345	815	37
August	127950	292	1665	77
September	91947	335	9451	141
October	32529	222	27158	207
November	8355	139	56812	283
December	2269	59	94694	321
<b>Total</b>	<b>657747</b>		<b>486352</b>	
<b>Hours at Peak</b>		<b>3.0</b>		<b>3.0</b>

### Hourly Loads Data

**Included:** Import Data File  
**Filename:** Report Example.zon